

## Accurate Controls Ltd.

25 Cowley Road, Nuffield Industrial Estate

Poole, Dorset, BH17 0UJ England

Tel: +44 (0) 1202 678108

email: info@accurate-controls.ltd.uk

web: www.accurate-controls.ltd.uk



LVDT mA Output Values Table

Accurate Controls LVDT mA Output Set Points								
Temp °C	0-10mA	0-10mA	2-10mA	2-10mA	0-20mA	0-20mA	4-20mA	4-20mA
0		0.00	2.00			0.00		4.00
10		0.67	2.53			1.33		5.07
20		1.33	3.07			2.67		6.13
30	0.00	2.00	3.60	2.00	0.00	4.00	4.00	7.20
40	0.83	2.67	4.13	2.67	1.67	5.33	5.33	8.27
50	1.67	3.33	4.67	3.33	3.33	6.67	6.67	9.33
60	2.50	4.00	5.20	4.00	5.00	8.00	8.00	10.40
70	3.33	4.67	5.73	4.67	6.67	9.33	9.33	11.47
80	4.17	5.34	6.27	5.34	8.33	10.67	10.67	12.53
90	5.00	6.00	6.80	6.00	10.00	12.00	12.00	13.60
100	5.83	6.67	7.33	6.67	11.67	13.33	13.33	14.67
110	6.67	7.34	7.87	7.34	13.33	14.67	14.67	15.73
120	7.50	8.00	8.40	8.00	15.00	16.00	16.00	16.80
130	8.33	8.67	8.93	8.67	16.67	17.33	17.33	17.87
140	9.17	9.34	9.47	9.34	18.33	18.67	18.67	18.93
150	10.00	10.00	10.00	10.00	20.00	20.00	20.00	20.00



Company Registered In England No. 2427774 VAT GB 541 786 035  
Registered Address: 24 Cecil Avenue, Bournemouth, Dorset, BH8 9EJ UK